

SPECIFICATION

TRIPLE LOCK BUCK DUCT FLEXIBLE ALUMINUM AIR DUCT

FLEXIBLE RIGID DUCT

- A. Flexible Duct shall be Flexmaster Triple Lock Buck Duct Flexible Air Duct (Insulated or Non-Insulated) as manufactured by Buckley Associates (781-878-5000) **Sheet Metal Union Local 17**. Flexible Duct Insulated (UL 181 Class 1 Air Duct) and Non-Insulated shall be Underwriters Laboratory Listed and constructed in accordance with N.F.P.A. Standards 90A and 90B. It shall have a smoke/flame spread rating 50/25.
- B. Triple Lock Duct shall be made from a tape of dead soft aluminum sheet, spiral wound into a tube and spiral corrugated to provide strength and stability. The joint shall consist of a air-tight seam. A double lock is **not** acceptable.
- C. Insulated Flex shall have a gray Fire Retardant Polyethylene outer jacket with a ½ lb. density 1½" thick Fiberglass Insulation blanket, factory wrapped.
- D. The Flexible Duct shall be supported as required.
- E. Flexible Duct work shall be rated at 12" Positive Pressure. Duct from 3" to 16" shall have a Negative Pressure of 12" , 8" for Duct work 18" and 20".
- F. All Flexible Duct shall be individually cartoned and labeled for delivery to the job site, for maximum protection.

*To maintain Buckley's policy of continuous improvement, we reserve the right to change prices, specifications, ratings or dimensions without notice or obligation. **Manufactured by Sheet Metal Union Local 17.***

MANUFACTURED BY: *Buckley Associates, Inc.* HANOVER, MA

MAIN OFFICE

HANOVER, MA
Phone (781) 878-5000
Fax (781) 871-9435

SALES AND WAREHOUSES

NEWINGTON, CT
Phone (860) 666-0555
Fax (860) 666-3035

STRATFORD, CT
Phone (203) 380-2405
Fax (203) 380-2151

MANCHESTER, NH
Phone (603) 669-3566
Fax (603) 669-2347

ALBANY, NY
Phone (518) 438-7423
Fax (518) 438-5527



Visit us on the World Wide Web at: <http://www.buckleyonline.com>

