

SPECIFICATION

BUCKLEY FIRE DAMPERS

MODEL 150 TYPE A & TYPE B

FIRE DAMPERS

Fire Dampers shall be installed in the Ductwork where indicated. Fire Dampers shall be constructed and installed with visible fusible links in accordance with the requirements of the National Board of Fire Underwriters and the Underwriters' Inspection Authorities having jurisdiction in the locality. Fire Dampers shall be Buckley Model 150A or 150B (vertical or horizontal) as manufactured by Buckley Associates (781-878-5000) **Sheet Metal Workers Local 17**. Dampers to meet National Fire Protection Association requirements as outlined in the current N.F.P.A. bulletin 90-A. Dampers shall bear the Underwriters' label. Dampers shall be installed with metal sleeves and framing angles. All Dampers shall be installed in accordance with the means by which they were U.L. tested.

Free area must equal or exceed that of the specified product.

*To maintain Buckley's policy of continuous improvement, we reserve the right to change prices, specifications, ratings or dimensions without notice or obligation. **Manufactured by Sheet Metal Union Local 17.***

MANUFACTURED BY: *Buckley Associates, Inc.* HANOVER, MA

Visit us on the World Wide Web at: <http://www.buckleyonline.com>

