



Dimensions


Quantity: 1 Width (in.): 24.00 Silencer Height (in.): 7.00
Weight (lb): Length (in.): 23.75



END VIEW



FRONT VIEW



ISO VIEW

Images are generic representations and not to scale. The actual configuration may not be shown.

Construction Options**Casing:** 24 GA Galvanneal**Acoustic Media:**1" Fiberglass Acoustic
Media**Notes**

- Performance data is derived from test values obtained in strict accordance with ASTM E477-13.
- Silencers are tested in our NVLAP-Accredited sound lab
- Price silencers consist of ASTM A653 / A653M steel casings and perforated liners.
- Price silencer material has flame spread classification < 25 and smoke development rating < 50 when tested in accordance with ASTM E84, UL723 and NFPA255.
- Customer to confirm all dimensions

PROJECT:
ENGINEER:
DESCRIPTION: Return Air Canopy
RAC-1-2//1//24x24/24.00/23.75/38.50/7.00/SC/FG1//

CUSTOMER:
UNIT OF MEASURE: Imperial

SUBMITTAL DATE: 6/24/2020
PRICE QUOTE NO: ~QUOTENO~
DRAWING REVISION:

United States Department of Commerce
National Institute of Standards and Technology



Certificate of Accreditation to ISO/IEC 17025:2017

NVLAP LAB CODE: 200874-0

Price Sound Laboratory

Winnipeg, Manitoba

Canada

*is accredited by the National Voluntary Laboratory Accreditation Program for specific services,
listed on the Scope of Accreditation, for:*

Acoustical Testing Services

*This laboratory is accredited in accordance with the recognized International Standard ISO/IEC 17025:2017.
This accreditation demonstrates technical competence for a defined scope and the operation of a laboratory quality
management system (refer to joint ISO-ILAC-IAF Communique dated January 2009).*

2019-06-17 through 2020-06-30

Effective Dates



A handwritten signature in blue ink, which appears to read 'Dana S. Haman'. The signature is written in a cursive style.

For the National Voluntary Laboratory Accreditation Program