SPECIFICATION

3300 TAKE-OFF

- A. Contractor shall provide a 3300 Take-off at all branch locations. The 3300 Take-off shall have a gasketed flange to provide an air-tight connection. The damper blade shall be a minimum of 26 Gauge Galvanized Steel. The 3300 shall be equal to that warehoused by Buckley Associates (781-878-5000).
- B. Residential quality 45 degree Take-off will *not* be accepted.

To maintain Buckley's policy of continuous improvement, we reserve the right to change prices, specifications, ratings or dimensions without notice or obligation. **Manufactured by Sheet Metal Union Local 17.**

MANUFACTURED BY: BUCKLEY ASSOCIATES, INC., HANOVER, MA

MAIN OFFICE

SALES AND WAREHOUSES

HANOVER, MA Phone (781) 878-5000 Fax (781) 871-9435 NEWINGTON, CT Phone (860) 666-0555 Fax (860) 666-3035 MANCHESTER, NH Phone (603) 669-3566 Fax (603) 669-2347 ALBANY, NY Phone (518) 438-7423 Fax (518) 438-5527

