Submittal Data


Hospital Grade Buct Duct Aluminum Silencer

Construction Features

Buckley's Hospital Grade Buck Duct Aluminum Silencer is comprised of an all-aluminum perforated core with an open area of 20-25%. The perforated inner duct is enclosed in a 2" thick fiberglass insulation and is isolated from the airstream by a UL approved seamless polyethylene liner. The outer jacket consists of Triple-Lock Aluminum Flexible Duct that is corrugated with mechanical interlocking seams to form an air tight, flexibal, metal duct. The end fittings are factory installed.

Technical Data

Standard Lengths (Feet)
UL ListingUL 181, Class 1 Air Duct
StandardsNFPA 90A AND 90B
CodesHUD/FHA MIN. Property Std.
Rated Velocity (F.P.M.)5500 F.P.M.
Internal Working Pressure (W.G.) 2" w.g. positive
1" w.g. negative
Minimum Burst Pressure2 ½ times working pressure
Operating Temperature Range60° to +250° F
Flame SpreadLess than 25
Smoke DevelopedLess than 50
R-Value6.0



Noise Reduction db (5' ft length, 8" inch diamater)

Octave Band	2	3	4	5	6	7	8
HZ	125	250	500	1000	2000	4000	8000
Model BDSHG Hospital Grade Buck Duct Aluminum Silencer	+2	-5	-13	-22	-12	-6	-8

About Our Tests

Our tests were conducted by Energistics Laboratory, an independent research development facility. All testing and rating procedures used by the laboratory are accordance with ARI, ADC, ISO, and ASHRAE standards as applicable. The results of the testing are based on test results of sound collected on various types of eight-inch round Buck Duct specimens. Each test sample was tested at a velocity of 500 FPM and was then compared to hard metal duct at the same velocity. For the purpose of these tests, the only comparison made is test specimens to hard duct.



